



Postal Address:  
 PO Box 4282  
 Dandenong South, Victoria 3164  
 Australia

Testing. Advising. Assuring.

<b>EWFA CERTIFICATE OF TEST</b>	<b>CERTIFICATE No : SFC 2715300.1</b>	<b>Page 1 of 1</b>
---------------------------------	---------------------------------------	--------------------

Report Sponsor	Certificate Issue Date
RMAX 2-4 Mephan Street Maribyrnong, VIC, 3032, Australia	06/08/12

**Introduction**

The element of construction described below was tested by this laboratory on behalf of the test sponsor in accordance with the stated test standard and achieved the results stated below. Refer to the referenced test report for more information.

Referenced Report	Test Date	Test Standard
EWFA 2715300.1	31/07/2012	AS1530.8.1-2007



Description of Product	
Test Specimen Arrangement	Rating
The specimen consisted of a nominal 3m x 3m timber stud framed wall system having a central area nominal 2m wide x 2.4m high offset 250mm back from the front face incorporating a sill and eaves details and an 800mm x 800mm aluminium framed window. The unexposed side was clad with 10mm thick Gyprock plasterboard while the exposed side had an 8.2mm thick RMAX Orange Board® Render system applied over 75mm thick RMAX Orange Board® EPS cladding. Refer to the test report for a full description.	<b>BAL A-29</b>

**Notes**

**THIS CERTIFICATE IS PROVIDED FOR GENERAL INFORMATION ONLY AND DOES NOT COMPLY WITH THE REGULATORY REQUIREMENTS FOR EVIDENCE OF COMPLIANCE.**

Reference should be made to the relevant test report to determine the applicability of the test result to a proposed installation and for a full description of the tested construction.

The results of these fire tests may be used to assess fire hazard, but it should be recognised that a single test method will not provide a full assessment of fire hazard under all conditions.

<b>TESTING AUTHORITY</b>	Exova Warringtonfire Aus Pty Ltd	
<b>Address</b>	PO Box 4282 DANDENONG SOUTH VIC 3164 Unit 2, 409-411 Hammond Road, DANDENONG VIC 3175	
<b>Phone / Fax</b>	+61 (0) 3 9767 1066 / +61 (0) 3 9767 1001	
<b>ABN</b>	81 050 241 524	
<b>Email / Home Page</b>	<a href="http://www.exova.com">www.exova.com</a>	
<b>Authorisation</b>	Prepared By:  M. Kamal	Reviewed By:  C. M. McLean